

			2012			2013			2014			2015			2016			2017		
Muuttuja	laatuvaatimus, enimmäisarvo	laatatavoite, enimmäisarvo	n	ka	max	n	ka	max	n	ka	max	n	ka	max	n	ka	max	n	ka	max
<i>Escherichia coli</i>	0 pmy/100 ml		6	0	0	10	0	0	8	0	0	8	0	0	8	0	0	7	0	0
koliformiset bakteerit		0 pmy/100 ml	6	0	0	10	0	0	8	0	0	8	0	0	8	0	0	7	0	0
pesäkkäiden lukumäärä 22 °C		ei muutoksia	5	1,2	5	10	0,6	2	8	1	2	8	0,14	1	4	2	4	7	1,7	6
pesäkkäiden lukumäärä 36 °C		ei muutoksia	1	0	0	1	0	0	1	0	0	1	0	0	1	0	0	1	0	0
haju ja maku		ei muutoksia	6			10			8			8			8			7		
väri/ulkonäkö		ei muutoksia	6			10			8			8	0,46	3,2	8	4	15	7	3,5	4,7
sameus		ei muutoksia	6	0,13	0,2	10	0,15	0,68	8	0,14	0,39	8	0,07	0,4	8	0,03	0,22	7	0,26	0,75
mangaani		50 µg/l	6	0	0	10	0	0	8	6,3	50	8	0	0	8	0	0	7	0	0
rauta		200 µg/l	6	0	0	10	0	0	8	0	0	8	0	0	8	3	24	7	1,7	12
pH	9,5	6,5 - 9,5	6	7,3	7,4	10	7,1	7,5	8	6,9	7,1	8	6,9	7	8	7,2	7,6	7	7,3	7,4
sähkönjohtavuus 20 °C		2 500 µS/cm	6	238	270	10	217	240	8	242	274	8	222	277	8	223	270	7	251	270
nitriitti (NO ₂ ⁻)	0,50 mg/l		1	0	0	1	0	0	1	0	0	1	0	0	1	0	0	1	0	0
kokonaiskovuus			1	0,76	1	2	0,79	0,86	1	0,87	1	0,87	0,5	0,5	1	0,68	0,68	1	0,63	0,63
alkaliteetti			1	1,1	1,1	2	1,2	1,3	1	1,1	1,1	1	1,1	1,1	1	1,6	1,6			
enterokokit	0 pmy/100 ml		1	0	0	1	0	0	1	0	0	1	0	0	1	0	0	1	0	0
kadmium	5,0 µg/l		1	0	0	1	0	0	1	0	0	1	0	0	1	0	0	1	0	0
kromi	50 µg/l		1	0	0	1	0	0	1	0	0	1	0	0	1	0	0	1	0	0
kupari	2,0 mg/l		1	0	0	1	0	0	1	0	0	1	0	0	1	0	0	1	0	0
lyijy	10 µg/l		1	0	0	1	0	0	1	0	0	1	0	0	1	0	0	1	0	0
nikkeli	20 µg/l		1	0	0	1	0	0	1	0	0	1	0	0	1	0	0	1	0	0
TOC		ei muutoksia	1	0	0	1	0	0	1	0	0	1	0	0	1	0	0	1	0	0
PAH yhteensä	0,10 µg/l		1	0	0													1	0	0
bentso(a)pyreeni	0,010 µg/l		1	0	0													1	0	0
antimoni	5,0 µg/l		1	0	0													1	0	0
hapettuvuus (COD _{Mn} -O ₂)		5,0 mg/l	1	0	0	1	0	0	1	0	0	1	0	0	1	0	0	1	0	0
akryyliamidi	0,10 µg/l																			
epikloorihydrini	0,10 µg/l																			
vinyylikloridi	0,50 µg/l		1	0	0													1	0	0
nitriitti (NO ₂ ⁻) lähtevä vesi	0,10 mg/l		1	0	0	1	0	0	1	0	0	1	0	0	1	0	0	1	0	0
alumiini		200 µg/l	1	6	6	1	0	0	1	0	0	1	0	0	1	0	0	1	0	0
ammonium (NH ₄ ⁺)		0,50 mg/l	1	0	0	1	0	0	1	0	0	1	0	0	1	0	0	1	0	0
natrium		200 mg/l	1	12	12	2	12	12	1	13	13	1	12	12	1	12	12	1	13	13
kloridi		250 mg/l	1	25	25	1	0	0	1	0	0	1	0	0	1	0	0	1	0	0
sulfaatti		250 mg/l	1	18	18	2	15,5	16	1	16	16	1	14	14	1	14	14	1	17	17
<i>Clostridium perfringens</i>		0 pmy/100 ml																		
trihalometaanit yhteensä	100 µg/l																			
bromaatti	10 µg/l		1	0	0	1	0	0												
arseeni	10 µg/l		1	0	0	1	0	0	1	0	0	1	0	0	1	0	0	1	0	0
elohopea	1,0 µg/l		1	0	0	1	0	0	1	0	0	1	0	0	1	0	0	1	0	0
fluoridi	1,5 mg/l		1	0,7	0,7	2	0,74	0,8	1	0,72	0,72	1	0,67	0,67	1	0	0	1	0,82	0,82
nitraatti (NO ₃ ⁻)	50 mg/l		1	0	0	1	0	0	1	0	0	1	0	0	1	0	0	1	0	0
bentseeni	1,0 mg/l		1	0	0													1	0	0
boori	1,0 mg/l		1	0	0													1	0	0
1,2-dikloorietaani	1,0 µg/l		1	0	0													1	0	0
seleeni	10 µg/l		1	0	0													1	0	0
syanidit	50 µg/l		1	0	0													1	0	0
tetrakloorieteeni ja trikloorieteeni yhteensä	10 µg/l		1	0	0													1	0	0
uraani	30 µg/l											1	2,5	2,5				1	1,8	1,8
torjunta-aineet, yhteensä	0,50 µg/l																			
radon	1000 Bq/l	300 Bq/l																		
tritium	100 Bq/l																			
viitteellinen annos	0,10 mSv/vuosi																			